

**From** Fire Station Officer  
SIRSA

**To** M/s ALOK SHARMA  
DAV POLICE PUBLIC SCHOOL POLICE LINES BARNALA ROAD SIRSA  
Memo No. FS/2020/2 dated : 27/01/2020

**Subject :** No objection Certificate Under 15 mtrs. from the fire safety point of view for Group B-Educational Building at POLICE LINES BARNALA ROAD SIRSA of DAV POLICE PUBLIC SCHOOL SIRSA :

Reference your letter no. 171021923000125 dated 09/12/2019 on the subject cited above.

| Tower Name                     | Floor Detail   | Height           | Ground Coverage   |
|--------------------------------|----------------|------------------|-------------------|
| DAV POLICE PUBLIC SCHOOL SIRSA | GROUND+1 FLOOR | 7.62 Meter       | 1385.93 Sq. Meter |
| Basement Level                 | Basement Area  | Basement Remarks |                   |
| Nil                            | Nil            | Nil              |                   |

- 1) All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 2) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 3) If any lapse or non functioning of fire system will be the sole responsibility of the owner/occupier.
- 4) All the means of escape shall be kept free of all the type of obstruction all the time.
- 5) All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 6) NOC granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved.
- 7) This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 8) The owner/occupier shall strictly follow the other applicable rules/by laws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions, This fire NOC will be deemed cancelled and you will be liable to be punish as per Fire Act-2009. chapter- 3, section- 31, sub-section 1 and 2.
- 9) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.

The above NOC is valid for only **One** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

**Remarks:-** Virification done by Deputy commissioner Sirsa Vide no 6271 LFA 31 12 2019



Fire Station Officer,  
SIRSA

Exercising the power of Director, Fire Services, Haryana



Digitally signed by DALBIR SINGH  
Date: 2020.01.27 20:27:31 +05:30  
Reason: Digital Verification